

2023 Annual Drinking Water Quality Report

Town of Fairview

PWSID# MT0000213

PO Box 426

Fairview, MT 59221

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is ground water from two wells. We have completed a source water protection plan that provides more information such as potential sources of contamination to our drinking water supply. This plan can be found online at <https://deq/mt/gov/water/Programs/dw-sourcewater>

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present include:

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems;

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

We're pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water, please contact **Dan Murphy**. He is a certified operator and can be reached at **406-742-5626**. You may also attend any of our meetings. They are held the **second Wednesday of each month at 7 PM**.

Fairview routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of any detects in our monitoring for the period of **January 1st to December 31st, 2023**. For constituents that are not monitored yearly, we have reviewed our records back the last five years.

Fairview has also been issued a waiver for certain inorganic contaminants. This waiver allows our water system to sample only once every 9 years for these regulated contaminants: barium, cadmium, chromium, mercury, selenium, and fluoride. Sampling in September of 2022 for these contaminants show that they are not present in our water supply or occur in such small amounts

that they are not considered a health hazard. This waiver is in effect from 1/1/2020 to 12/31/2028.

We have monitored for lead and copper and all our samples have been in compliance with the Lead and Copper Rule. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Fairview is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Parameter	Date	90th % value	Units	Action level	Source of Contamination
Copper	2023	1.28	ppm	1.3	Household plumbing
Lead	2023	<1	ppb	15	Household plumbing

In the tables above and below you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2000 years or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Action Level - the concentration of a contaminant which if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (mandatory language) The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Picocuries per liter (pCi/L)-Picocuries per liter is a measure of the radioactivity in water.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

TEST RESULTS								
Contaminant	Violation Y/N	Sample Date	Highest Level Detected		Unit Measurement	MCLG	MCL	Likely Source of Contamination
Disinfection By-products								
Chlorine	N	2023	0.92		ppm	MRDLG 4	MRDL 4	Water additive used to control microbes
Total Trihalomethanes (TTHMs)	N	2023	66		ppb	0	80	By-product of drinking water chlorination
Haloacetic Acids (HAAs)	N	2023	56		ppb	0	60	By-product of drinking water chlorination
Radioactive Contaminants								
Uranium	N	2022	0.6		ppb	0	30	Erosion of natural deposits
Inorganic Contaminants								
Fluoride	N	2022	2.2		ppm	4	4	Erosion of natural deposits

Our system had several violations.

Violations			
Violation for Montana State Chlorine Rule			
Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.			
Violation Type	Violation Period	Resolution Date	Violation Explanation
STATE CHLORINE MONITORING DAILY	03/01/2023 to 03/31/2023	05-08-2023	We failed to monitor and record the daily minimum entry point chlorine residuals and report them to DEQ. Because of this, we cannot be sure of the water quality at this time.
The violation was returned to compliance once the system submitted one full months of data by 10th of the following month, and for said month, the system did not have any days with a chlorine residual below the mandatory level.			
STATE CHLORINE MONITORING DAILY	05/01/2023 to 05/31/2023	07-04-2023	We failed to monitor and record the daily minimum entry point chlorine residuals and report them to DEQ. Because of this, we cannot be sure of the water quality at this time.
The violation was returned to compliance once the system submitted one full months of data by 10th of the following month, and for said month, the system did not have any days with a chlorine residual below the mandatory level.			
STATE CHLORINE MONITORING DAILY	10/01/2023 to 10/31/2023	12-05-2023	We failed to monitor and record the daily minimum entry point chlorine residuals and report them to DEQ. Because of this, we cannot be sure of the water quality at this time.
The violation was returned to compliance once the system submitted one full months of data by 10th of the following month, and for said month, the system did not have any days with a chlorine residual below the mandatory level.			

Violation for Nitrate and nitrite [measured as Nitrogen]

Infants below the age of six months who drink water containing nitrate and nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Violation Type	Violation Period	Resolution Date	Violation Explanation
MONITORING, ROUTINE MAJOR	01/01/2023 to 12/31/2023	01-30-2024	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

We have taken the necessary samples, albeit late, to return to compliance.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water **IS SAFE** at these levels.

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This Annual Drinking Water Quality Report **will not** be mailed out to individual water customers. If you would like a copy of this report, you may call the Town Clerk at 742-5616.